



SOUTH AFRICAN TOURISM

RESPONSE TO BIDDER QUERIES TENDER NO: SAT 286/25 Description: REFURBISHMENT, CONSTRUCTION, AND UPGRADE OF SA TOURISM HEAD OFFICE.				
No	Document	Page	Item	Query
1	SAT286-25-Building Works-BoQ-V3	45	3	Product discontinued
				Reference to a supplier is for illustrative purposes and bidders may quote based on other suppliers, provided the product has a similar specification. Edit sub-heading to read: 500 x 500mm commercial carpet tiles (solution dyed nylon, tufted tile) with Use Classification EN1307 Heavy Commercial and 15-year limited wear warranty, ± 5.5mm total thickness, installed by approved installer in accordance with SANS 10186:2010, the code of practice for textile floor coverings (Ref FF6)
2	SAT286-25-Building Works-BoQ-V3	45	4	Product discontinued
				Reference to a supplier is for illustrative purposes and bidders may quote based on other suppliers, provided the product has a similar specification. Edit sub-heading to read: 500 x 500mm commercial carpet tiles (solution dyed nylon, tufted tile) with Use Classification EN1307 Heavy Commercial and 15-year limited wear warranty, ± 5.5mm total thickness, installed by approved installer in accordance with SANS 10186:2010, the code of practice for textile floor coverings (Ref FF9)



SOUTH AFRICAN TOURISM

RESPONSE TO BIDDER QUERIES TENDER NO: SAT 286/25 Description: REFURBISHMENT, CONSTRUCTION, AND UPGRADE OF SA TOURISM HEAD OFFICE.				
No	Document	Page	Item Query	Response/ Action
3	SAT286-25-Building Works-BoQ-V3	46	5 Product discontinued	Reference to a supplier is for illustrative purposes and bidders may quote based on other suppliers, provided the product has a similar specification. Edit sub-heading to read: Luxury woodplank vinyl floor tiles size 184 x 1219 x 2,0mm thick (Use Classification Heavy Commercial), with a 0,55mm clear wear layer laid in an approved adhesive spread with a notched trowel on suitably prepared cement screed with a hygrometer reading showing a moisture content of less than 70% and rolled with 68kg articulated floor roller, all in accordance with manufacturer's recommendations (Ref FF4 - Belgotex or similar approved
4	SAT286-25-Building Works-BoQ-V3	47	8 Product discontinued	Reference to a supplier is for illustrative purposes and bidders may quote based on other suppliers, provided the product has a similar specification. Edit sub-heading to read: 2mm thick vinyl floor sheeting (Use Classification EN1307 Heavy Commercial), laid in conductive acrylic adhesive spread with a notched trowel on suitably prepared cement screed with a hygrometer reading



SOUTH AFRICAN TOURISM

RESPONSE TO BIDDER QUERIES TENDER NO: SAT 286/25 Description: REFURBISHMENT, CONSTRUCTION, AND UPGRADE OF SA TOURISM HEAD OFFICE.				
No	Document	Page	Item Query	Response/ Action
				showing a moisture content of less than 70%, with joints welded with a fully flexible welding rod to provide a smooth, hygienic sealed finish and rolled with 68kg articulated floor roller, all in accordance with manufacturer's recommendations (Ref FF8 - Belgotex or similar approved)